

Structural vulnerability of the North American power grid

Réka Albert,^{1,2} István Albert,² and Gary L. Nakarado³

¹*Department of Physics, Pennsylvania State University, University Park, Pennsylvania 16802, USA*

²*Huck Institute for Life Sciences, Pennsylvania State University, University Park, Pennsylvania 16802, USA*

³*National Renewable Energy Laboratory, Golden, Colorado 80401, USA*

(Received 13 October 2003; published 26 February 2004)

The magnitude of the August 2003 blackout affecting the United States has put the challenges of energy transmission and distribution into limelight. Despite all the interest and concerted effort, the complexity and interconnectivity of the electric infrastructure precluded us for a long time from understanding why certain events happened. In this paper we study the power grid from a network perspective and determine its ability to transfer power between generators and consumers when certain nodes are disrupted. We find that the power grid is robust to most perturbations, yet disturbances affecting key transmission substations greatly reduce its ability to function. We emphasize that the global properties of the underlying network must be understood as they greatly affect local behavior.

DOI: 10.1103/PhysRevE.69.025103

PACS number(s): 89.75.Fb, 02.10.Ox, 84.70.+p, 89.75.Hc

During the past decades the North American power infrastructure has evolved into what many experts consider the largest and most complex system of the technological age. Geographically, the power grid forms a network of over 10^6 km of high voltage lines that are continuously regulated by sophisticated flow control equipment. As a result of the recent deregulation of power generation and transmission, about one-half of all domestic generation is now sold over ever-increasing distances on the wholesale market before it is delivered to customers [1]. Consequently the power grid is witnessing power flows in unprecedented magnitudes and directions [2].

As the power grid increases in size and complexity, it is becoming more important to understand the emergent behaviors that can take place in the system. Performing an analytic description of the electromagnetic processes integrated over the whole grid is a daunting, if not impossible, task. Instead the power industry must resort to constructing models that can be used to simulate the network's response to various external parameters. Generally these models attempt to simulate actual electrical flow characteristics in smaller systems such as a single distribution grid [3]. In the present analysis we propose an alternative approach based on recent advances in understanding the structure of large complex networks [4]. We choose to investigate the network representation of the power grid from a topological perspective with the hope of finding properties and behaviors that transcend the abstraction.

We have built the network model based on data stored in the POWERmap mapping system developed by Platts [5], the energy information and market services unit of the McGraw-Hill Companies. This mapping system contains information about every power plant, major substation, and 115–765 kV power line of the North American power grid. Our model represents the power grid as a network of 14 099 nodes (substations) and 19 657 edges (transmission lines). We distinguish three types of substations: generators are the sources for power, transmission substations transfer the power among high-voltage transmission lines, and distribution substations are at the outer edge of the transmission grid,

and the centers of local distribution grids. Only the identity of generating substations was directly available from our data sources. We identify distribution substations by the criterion of having a single high-voltage transmission line connected to them, with the expectation that the flow out of them is continued on smaller voltage feeder lines leading to consumers [6]. A total of 1633 nodes are power plants, we classify 2179 nodes as distributing substations, with the rest being labeled as transmission substations.

We consider the power from a generator to be accessible to a consumer if there is a path of transmission lines between the two. In practice, the existence of a connection between two substations does not always imply that power can be transferred across it as there may be capacity or other constraints present. By ignoring these our model provides an idealized view, a best case scenario regarding the characteristics of the grid. We find that the network representation of the power grid contains a single connected component, meaning that there is a path of transmission lines between any power plant and any distribution substation. This observation implies that in the best case scenario each distribution substation can possibly receive power from any generator.

Recent advances in mapping the topology of complex networks have uncovered that a large fraction of them are highly heterogeneous with respect to the number of edges incident on a node (also called the node degree). In these networks the majority of the nodes have low degrees, but there is a continuous hierarchy of high-degree nodes (hubs) that play an important role in the system. The degree distribution of these networks follows a power law $P(k) \sim k^{-\gamma}$ with the exponent γ mostly between 2 and 3. It was demonstrated both numerically and analytically that these so-called scale-free networks are resilient to the random loss of nodes, but are vulnerable to attacks targeting the high-degree hubs [7–9]. Therefore it is important both from a theoretical and practical standpoint to determine whether the connectivity of the power grid is reliant on a small set of hubs and whether their loss will cause a large-scale breakdown of the power grid's transmission capability.




FIG. 1. The probability that a substation has more than K transmission lines. The straight line represents the exponential function (1). Inset: the fraction $F_g(k)$ of generating substations among substations with degree k .

As the node degree is a good indicator of its topological importance, we first determine the degree distribution of the power grid. We find that the cumulative degree distribution defined as $P(k > K) = \sum_{k > K} P(k)$ follows an exponential

$$P(k > K) \sim \exp(-0.5K) \quad (1)$$

(see Fig. 1). This functional form agrees with previous results on the degree distribution of the western power grid [10] and its classification as a single-scale network. The cumulative degree distribution shows that the probability of high-degree nodes is less than in a scale-free network, but higher than in a random network with the same number of nodes and edges. Power engineering principles suggest that the hubs of the power grid should belong to central station generators, and transmission substations should not have more than a few edges. Indeed, the inset to Fig. 1 shows that the fraction of generating substations among substations of a given degree increases with this degree. Surprisingly, however, there are several high-degree transmission substations (e.g., 50 have degree higher than 10), including the node with highest degree.

As the role of the power grid is to transport power from generators to consumers, a possible measure for the importance of a node corresponding to a substation is its betweenness (or load) [11,12]. The betweenness of a node in a network is defined as the number of shortest paths that traverse it [11,12]. Assuming that power is routed through the most direct path, the betweenness of a substation is a proxy for how much power it is transmitting, and for this reason we will use the alternative term load to denote it. Since it is the transmission substations' role to route power from generators to distribution substations, we focus our attention to them. We determine the shortest paths starting from all generation substations and ending on an all other reachable substations. For each transmission node we accumulate the number of paths that pass through it; being at the start or at the end of a path does not count. The highest possible load is $1633 \times 12466 \approx 20 \times 10^6$. We find that substations can have a load anywhere between 1 and 4×10^6 , and determine the cumulative load distribution, i.e., the probability that a node's load




FIG. 2. The probability that a substation has more than L transmission paths passing through it. The continuous curve has the generalized power law form (2). Inset: histogram of the length of the shortest alternative path r between the end points of an edge. In order to be able to include edges with no alternative path, the abscissa is inverted.

l is larger than a given value L (see Fig. 2). The functional form of the cumulative load distribution is

$$P(l > L) \sim (2500 + L)^{-0.7}. \quad (2)$$

Figure 2 illustrates that 40% of the substations participate in tens or hundreds of paths only, but 1% of them are part of 10^6 or more paths. These high-load substations, although possibly not hubs regarding their degree, play an important role in power transmission.

A fundamental requirement of the power grid is robustness, the ability to withstand and tolerate errors (random failure) and targeted attacks [7–9]. To ensure the reliability of power distribution, the transmission grid was conceived in such a way that there is more than one electrical path between any two points in the system [13]. We wanted to verify whether the actual topology of the current power grid has this feature of global redundancy, or it has lost it during its growth and evolution. A possible measure of network redundancy is the so-called edge range, defined as the distance between the two end points of an edge if the edge connecting them were removed [14]. The inset of Fig. 2 shows the frequency of different edge ranges r plotted as a function of r^{-1} . We find that parallel edges and short alternative paths are fairly frequent. However, around 15% of the edges in the power grid have an infinite range. In addition to the 2179 edges ending in distribution substations, close to 900 edges connecting generators and/or transmission substations are radial. These radial edges represent a clear vulnerability, as their loss disconnects their end points and creates isolated clusters in the power grid.

While the connectedness of the power grid allows for the transmission of power over large distances, it also implies that local disturbances propagate over the whole grid. The failure of a power line due to lightning strike or short-circuit leads to the overloading of parallel and nearby lines. Power lines are guarded by automatic devices that take them out of

service when the voltage on them is too high. Generating substations are designed to switch off if their power cannot be transmitted; this protective measure has the unwanted effect of diminishing power for all consumers. Another possible consequence of power line failure is the incapacitation of transmission substations, possibly causing that the power from generators cannot reach distribution substations and ultimately consumers.

In the unperturbed state each distribution substation can receive power from any of the $N_g = 1633$ generators. As substations lose function, the number of generators connected to (and able to feed) a certain distribution substation i , N_g^i , decreases. We introduce the concept of connectivity loss C_L to quantify the average decrease in the number of generators connected to a distributing substation,

$$C_L = 1 - \left\langle \frac{N_g^i}{N_g} \right\rangle_i, \quad (3)$$

where the averaging is done over every distributing substation. In summary, the connectivity loss measures the decrease of the ability of distribution substations to receive power from the generators, and in the following we will express it as a percentage.

First we investigate the effect that the failure of a power-generating substation has on consumers. Since initially the network contains a single connected component every consumer can receive power from each generator, and their connectivity is 100%. As the number of generators decreases, consumer connectivity will decrease due to both loss of the generators themselves and loss of routing capabilities at the generating substation level. We remove nodes corresponding to generators either randomly, or in the decreasing order of their degrees, and monitor the connectivity loss as a function of the fraction of generators missing. The minimum possible loss is equal to the fraction f_g of inactive generators and is due to the loss in generation only (straight line in Fig. 3). We find that the connectivity loss caused by removing power substations remains close to this minimum value (Fig. 3), even though generating substations tend to be the largest hubs in the system. The removal of generating substations does not alter the overall connectivity of the grid thanks to a high level of redundancy at the power generating substation level.

The situation can be dramatically different when the nodes that we remove are transmission nodes. If the power grid were highly redundant the loss of a small number of transmission substations should not cause power loss as power is rerouted through alternative paths. We find that even the removal of a single transmission node causes a slight connectivity loss. We remove transmission nodes one by one, first randomly, then in the decreasing order of their degree or load. For a random failure the connectivity loss is fairly low and stays proportional with the number of nodes lost. The connectivity loss is significantly higher, however, when targeting high degree or high load transmission hubs (Fig. 4). The grid can withstand only a few failures of this nature before considerable parts of the network become disconnected leading to substantial connectivity loss at con-




FIG. 3. Connectivity loss in the power grid resulting from the failure of a fraction f_g of generators. The straight line represents the minimum loss due to the node removal itself. Circles, random removal of generators; triangles, removal starting from the highest-degree generators. The curves are averages of ten runs, where either the list of generators or the list of generators with the same degree was randomly permuted.

sumer level. For example, failure of only 4% of the nodes with high load may cause up to 60% loss of connectivity. We also study an algorithm where we periodically recalculate the load of all transmission nodes during node removal, and select the nodes with highest load to be deleted next. This is a possible illustration of a propagating (cascading) power failure [15–17], where it is more likely that substations that have the highest load in the perturbed configuration will fail next. Figure 4 illustrates that this cascading failure has the most damaging effect, as the loss of only 2% of the high-load transmission substations leads to a connectivity loss of almost 60%, and all distribution substations become virtually powerless at $f_t \approx 8\%$. In conclusion, the transmission hubs ensuring the connectivity of the power grid are also its largest liability in case of power breakdowns.




FIG. 4. Connectivity loss in the power grid due to the removal of nodes corresponding to transmission substations. We remove a fraction f_t of transmission nodes with four different algorithms: randomly (circles), in the decreasing order of their degrees (triangles) or loads (diamonds), and by recalculating the load every ten steps and removing the ten nodes with highest load (squares). The curves corresponding to random and degree-based node removal were averaged over ten runs. The load-based and cascading removal curves represent a single run.

This vulnerability of the electric power grid is inherent to its organization and therefore cannot be easily addressed without significant investment. Possible solutions include increasing the redundancy and capacity of the existent structure or decreasing the reliance on transmission by incorporating more generation at the distribution substation level. Such distributed generation by small local plants can supplement power from the grid under normal operation conditions

and can greatly mitigate the effects of blackouts on the population. Targeted use of generation located near the point of use might prove to be the only viable economical alternative.

The authors wish to thank Donna Heimiller and Steven Englebretson for their help in obtaining the POWERmap network data. This research was partially supported by the Midwest Research Institute (MRI, Contract No. AAX-3-33641-01).

-
- [1] Electricity Technology Roadmap, 1999 Summary and Synthesis, by the Electric Power Research Institute, <http://www.nerc.com/~filez/rasreports.html>
- [2] North American Electricity Reliability Council reliability assessment report, 1998, <http://www.nerc.com/~filez/rasreports.html>
- [3] Dromey Design electrical distribution analysis software, <http://www.dromeydesign.com/dess/lfa.htm>
- [4] R. Albert and A.-L. Barabási, *Rev. Mod. Phys.* **74**, 47 (2002); A.-L. Barabási, *Linked: The New Science of Networks* (Perseus, Cambridge, 2002); D. J. Watts, *Six Degrees: The Science of a Connected Age* (Norton, New York, 2003); S. N. Dorogovtsev and J. F. F. Mendes, *Evolution of Networks: From Biological Nets to the Internet and WWW* (Oxford University Press, Oxford, 2003); M.E.J. Newman, *SIAM Rev.* **45**, 167 (2003).
- [5] Platts Global Energy, <http://www.platts.com/electricpower/index.shtml>
- [6] This method may miss distribution substations with more than one incoming transmission line. Unfortunately no information regarding the directionality of the transmission lines was available from our data sources.
- [7] R. Albert, H. Jeong, and A.-L. Barabási, *Nature (London)* **406**, 378 (2000).
- [8] R. Cohen, K. Erez, D. ben-Avraham, and S. Havlin, *Phys. Rev. Lett.* **85**, 4626 (2000); **86**, 3682 (2001).
- [9] D.S. Callaway, M.E.J. Newman, S.H. Strogatz, and D.J. Watts, *Phys. Rev. Lett.* **85**, 5468 (2000).
- [10] L.A.N. Amaral, A. Scala, M. Barthélémy, and H.E. Stanley, *Proc. Natl. Acad. Sci. U.S.A.* **97**, 11 149 (2000).
- [11] K.-I. Goh, B. Kahng, and D. Kim, *Phys. Rev. Lett.* **87**, 278701 (2001).
- [12] M.E.J. Newman, *Phys. Rev. E* **64**, 016132 (2001).
- [13] H. Saadat, *Power System Analysis* (McGraw-Hill, Boston, 1999).
- [14] A.E. Motter, T. Nishikawa, and Y.-C. Lai, *Phys. Rev. E* **66**, 065103(R) (2002).
- [15] A. Motter and Y.C. Lai, *Phys. Rev. E* **66**, 065102(R) (2002).
- [16] Y. Moreno, R. Pastor-Satorras, A. Vázquez, and A. Vespignani, *Europhys. Lett.* **62**, 292 (2003).
- [17] P. Crucitti, V. Latora, and M. Marchiori, e-print cond-mat/0309141.